

MasterWorks - 130 Cedar Building, Community Monitoring																							
Sample No.	Sampling Location	Collection Start Date	Collection Time (am/pm)	Collection End Date	Collection Time (am/pm)	Total collection time, minutes	Sample Volume (liters)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Total Structure Count			Asbestos < 5 µm	Asbestos ≥ 5 µm	Result (µm/m ³)	Concentration (Boc)	EPA Site Specific Trigger Level	Exceeds EPA Site Specific Trigger Level?	Comments		
												All Asbestos	Crystalline	Amphibole									
5267526	3-90 West Courtyard at 2nd Floor Level	12/30/2007	7:11 AM	12/30/2007	11:11 AM	260	1,320	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/2/2008	1	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5267526	4-Abary St 6th Floor Scalloping	12/30/2007	7:00 AM	12/30/2007	11:19 AM	259	1,308	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/2/2008	1	1	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5267527	5- Washington St 6th Floor Scalloping	12/30/2007	7:01 AM	12/30/2007	11:20 AM	259	1,295	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/2/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5267528	6- Cedar St 6th Floor Scalloping	12/30/2007	7:02 AM	12/30/2007	11:20 AM	259	1,295	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/2/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5267529	7- Roof, East Facade	12/30/2007	7:05 AM	12/30/2007	11:24 AM	259	1,295	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/2/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5267530	8- Roof, North Facade	12/30/2007	7:06 AM	12/30/2007	11:25 AM	259	1,295	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/2/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5269817	3-90 West Courtyard at 2nd Floor Level	12/31/2007	7:19 AM	12/31/2007	2:42 PM	443	2,214	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/2/2008	0	0	0	0	0	7.8	< 0.019	70 µm/m ³	No			
5269842	4-Abary St 6th Floor Scalloping	12/31/2007	7:04 AM	12/31/2007	2:47 PM	443	1,667	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/2/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5269843	5- Washington St 6th Floor Scalloping	12/31/2007	7:05 AM	12/31/2007	2:48 PM	443	1,644	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/2/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5269844	6- Cedar St 6th Floor Scalloping	12/31/2007	7:07 AM	12/31/2007	2:44 PM	443	1,644	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/2/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5269845	7- Roof, East Facade	12/31/2007	7:09 AM	12/31/2007	2:55 PM	446	1,631	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/2/2008	0	0	0	0	0	6.5	< 0.02	70 µm/m ³	No			
5269846	8- Roof, North Facade	12/31/2007	7:10 AM	12/31/2007	2:56 PM	446	1,666	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/2/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5270859	3-90 West Courtyard at 2nd Floor Level	1/1/2008	7:28 AM	1/1/2008	12:04 PM	289	1,530	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/3/2008	0	0	0	0	0	7.8	< 0.019	70 µm/m ³	No			
5270860	4-Abary St 6th Floor Scalloping	1/1/2008	7:07 AM	1/1/2008	12:17 PM	279	1,500	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/3/2008	0	0	0	0	0	7.8	< 0.02	70 µm/m ³	No			
5270861	5- Washington St 6th Floor Scalloping	1/1/2008	7:29 AM	1/1/2008	12:18 PM	289	1,517	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/3/2008	0	0	0	0	0	7.8	< 0.02	70 µm/m ³	No			
5270862	6- Cedar St 6th Floor Scalloping	1/1/2008	7:31 AM	1/1/2008	12:18 PM	287	1,543	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/3/2008	0	0	0	0	0	7.8	< 0.019	70 µm/m ³	No			
5270863	7- Roof, East Facade	1/1/2008	7:46 AM	1/1/2008	11:57 AM	251	1,255	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/3/2008	0	0	0	0	0	6.5	< 0.02	70 µm/m ³	No			
5270864	8- Roof, North Facade	1/1/2008	7:48 AM	1/1/2008	11:58 AM	250	1,250	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/3/2008	0	0	0	0	0	6.5	< 0.02	70 µm/m ³	No			
5269847	3-90 West Courtyard at 2nd Floor Level	1/2/2008	7:40 AM	1/2/2008	1:33 PM	473	1,623	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/3/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5269848	4-Abary St 6th Floor Scalloping	1/2/2008	7:30 AM	1/2/2008	1:32 PM	473	1,679	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/3/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5269849	5- Washington St 6th Floor Scalloping	1/2/2008	7:31 AM	1/2/2008	1:34 PM	473	1,703	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/3/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5269849	6- Cedar St 6th Floor Scalloping	1/2/2008	7:32 AM	1/2/2008	1:37 PM	475	1,686	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/3/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5267778	7- Roof, East Facade	1/2/2008	7:36 AM	1/2/2008	1:33 PM	477	1,681	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/3/2008	1	1	0	1	0	8.3	0.019	70 µm/m ³	No			
5269850	8- Roof, North Facade	1/2/2008	7:38 AM	1/2/2008	1:35 PM	477	1,693	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/3/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5269826	3-90 West Courtyard at 2nd Floor Level	1/2/2008	3:44 PM	1/3/2008	12:25 AM	521	1,860	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/4/2008	0	0	0	0	0	9	< 0.019	70 µm/m ³	No			
5269827	4-Abary St 6th Floor Scalloping	1/2/2008	3:23 PM	1/3/2008	12:43 AM	550	1,960	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/4/2008	0	0	0	0	0	9.7	< 0.019	70 µm/m ³	No			
5269828	5- Washington St 6th Floor Scalloping	1/2/2008	3:24 PM	1/3/2008	12:44 AM	560	1,932	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/4/2008	0	0	0	0	0	9.7	< 0.019	70 µm/m ³	No			
5269829	6- Cedar St 6th Floor Scalloping	1/2/2008	3:27 PM	1/3/2008	12:46 AM	559	1,943	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/4/2008	0	0	0	0	0	9.7	< 0.019	70 µm/m ³	No			
5269830	7- Roof, East Facade	1/2/2008	3:33 PM	1/3/2008	12:30 AM	537	1,880	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/4/2008	0	0	0	0	0	9.7	< 0.02	70 µm/m ³	No			
5269831	8- Roof, North Facade	1/2/2008	3:35 PM	1/3/2008	12:31 AM	536	1,876	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/4/2008	1	1	0	1	0	9.7	0.02	70 µm/m ³	No			
5269815	3-90 West Courtyard at 2nd Floor Level	1/3/2008	7:40 AM	1/3/2008	1:29 PM	488	1,720	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/4/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5269816	4-Abary St 6th Floor Scalloping	1/3/2008	7:06 AM	1/3/2008	1:16 PM	490	1,752	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/4/2008	0	0	0	0	0	6.5	< 0.02	70 µm/m ³	No			
5269817	5- Washington St 6th Floor Scalloping	1/3/2008	7:07 AM	1/3/2008	1:14 PM	487	1,753	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/4/2008	0	0	0	0	0	6.5	< 0.02	70 µm/m ³	No			
5269818	6- Cedar St 6th Floor Scalloping	1/3/2008	7:08 AM	1/3/2008	1:11 PM	483	1,739	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/4/2008	0	0	0	0	0	6.5	< 0.02	70 µm/m ³	No			
5269819	7- Roof, East Facade	1/3/2008	7:11 AM	1/3/2008	1:19 PM	488	1,757	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/4/2008	0	0	0	0	0	6.5	< 0.02	70 µm/m ³	No			
5269820	8- Roof, North Facade	1/3/2008	7:12 AM	1/3/2008	1:22 PM	490	1,754	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/4/2008	2	2	0	1	1	17.9	0.038	70 µm/m ³	No			
5269859	3-90 West Courtyard at 2nd Floor Level	1/3/2008	3:29 PM	1/3/2008	9:48 PM	380	1,330	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/5/2008	0	0	0	0	0	6.8	< 0.02	70 µm/m ³	No			
5269860	4-Abary St 6th Floor Scalloping	1/3/2008	3:16 PM	1/3/2008	11:04 PM	468	1,638	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/5/2008	0	0	0	0	0	6.5	< 0.02	70 µm/m ³	No			
5269861	5- Washington St 6th Floor Scalloping	1/3/2008	3:14 PM	1/3/2008	11:10 PM	472	1,679	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/5/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5269862	6- Cedar St 6th Floor Scalloping	1/3/2008	3:11 PM	1/3/2008	11:09 PM	476	1,673	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/5/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5269863	7- Roof, East Facade	1/3/2008	3:19 PM	1/3/2008	11:14 PM	475	1,615	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/5/2008	0	0	0	0	0	6.5	< 0.02	70 µm/m ³	No			
5269864	8- Roof, North Facade	1/3/2008	3:22 PM	1/3/2008	11:18 PM	476	1,618	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/5/2008	0	0	0	0	0	6.5	< 0.02	70 µm/m ³	No			
5269848	3-90 West Courtyard at 2nd Floor Level	1/3/2008	9:49 AM	1/4/2008	7:44 AM	595	2,053	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/5/2008	0	0	0	0	0	10.6	< 0.02	70 µm/m ³	No			
5269849	4-Abary St 6th Floor Scalloping	1/3/2008	11:04 PM	1/4/2008	7:18 AM	494	1,754	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/5/2008	0	0	0	0	0	6.5	< 0.02	70 µm/m ³	No			
5269850	5- Washington St 6th Floor Scalloping	1/3/2008	11:06 PM	1/4/2008	7:25 AM	496	1,741	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/5/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5269851	6- Cedar St 6th Floor Scalloping	1/3/2008	11:09 PM	1/4/2008	7:28 AM	496	1,711	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/5/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5269852	7- Roof, East Facade	1/3/2008	11:14 PM	1/4/2008	7:34 AM	500	1,750	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/5/2008	0	0	0	0	0	6.5	< 0.02	70 µm/m ³	No			
5269853	8- Roof, North Facade	1/3/2008	11:18 PM	1/4/2008	7:36 AM	500	1,765	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/5/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5269826	3-90 West Courtyard at 2nd Floor Level	1/4/2008	7:44 AM	1/4/2008	3:38 PM	472	1,676	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/5/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5269827	4-Abary St 6th Floor Scalloping	1/4/2008	7:18 AM	1/4/2008	3:51 PM	513	1,821	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/5/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5269828	5- Washington St 6th Floor Scalloping	1/4/2008	7:20 AM	1/4/2008	3:52 PM	512	1,825	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/5/2008	0	0	0	0	0	6.5	< 0.019	70 µm/m ³	No			
5269829	6- Cedar St 6th Floor Scalloping	1/4/2008	7:25 AM	1/4/2008	3:54 PM	509	1,782	Asbestos	AMERA, 40 CFR, Part 763, October 30, 1987 (Modified)	RJLG TEM	1/5/2008	0											

MasterWorks - 130 Cedar Building, Community Monitoring															
Sample No.	Sampling Location	Collection Start Date	Collection (Time on)	Collection End Date	Collection (Time off)	Total Collection Time, minutes	Volume (liters)	Analysis	Analytical Method	Lab	Lab Sample Receipt Date	Mercury Concentration (ng/m ³)	EPA Site Specific Trigger Level for Mercury (ng/m ³)	Exceeds Target Air Quality or EPA Site Specific Level?	Comments
5268146	3 - 90 West Courtyard at 2nd Floor Level	12/30/2007	7:34 AM	12/31/2007	7:08 AM	1,414	566	Mercury	EPA 324/1631 mod.	BRL	01/02/2008	< 5	3000 ng/m ³	No	
5268150	4 - Albany St 6th Floor Scaffolding	12/30/2007	7:51 AM	12/31/2007	7:31 AM	1,420	568	Mercury	EPA 324/1631 mod.	BRL	01/02/2008	< 5	3000 ng/m ³	No	
5268154	5 - Washington St 6th Floor Scaffolding	12/30/2007	8:06 AM	12/31/2007	7:45 AM	1,419	561	Mercury	EPA 324/1631 mod.	BRL	01/02/2008	< 5	3000 ng/m ³	No	
5268158	6 - Cedar St 6th Floor Scaffolding	12/30/2007	8:20 AM	12/31/2007	8:00 AM	1,420	561	Mercury	EPA 324/1631 mod.	BRL	01/02/2008	< 5	3000 ng/m ³	No	
5268162	7 - Roof, East Facade	12/30/2007	7:27 AM	12/31/2007	6:56 AM	1,409	543	Mercury	EPA 324/1631 mod.	BRL	01/02/2008	< 6	3000 ng/m ³	No	
5268166	8 - Roof, North Facade	12/30/2007	7:51 AM	12/31/2007	7:32 AM	1,421	554	Mercury	EPA 324/1631 mod.	BRL	01/02/2008	< 6	3000 ng/m ³	No	
5269851	3 - 90 West Courtyard at 2nd Floor Level	12/31/2007	7:12 AM	1/1/2008	8:49 AM	1,537	576	Mercury	EPA 324/1631 mod.	BRL	01/03/2008	10	3000 ng/m ³	No	
5269855	4 - Albany St 6th Floor Scaffolding	12/31/2007	7:34 AM	1/1/2008	7:46 AM	1,452	545	Mercury	EPA 324/1631 mod.	BRL	01/03/2008	11	3000 ng/m ³	No	
5269859	5 - Washington St 6th Floor Scaffolding	12/31/2007	7:49 AM	1/1/2008	8:00 AM	1,451	580	Mercury	EPA 324/1631 mod.	BRL	01/03/2008	11	3000 ng/m ³	No	
5269863	6 - Cedar St 6th Floor Scaffolding	12/31/2007	8:04 AM	1/1/2008	8:19 AM	1,455	582	Mercury	EPA 324/1631 mod.	BRL	01/03/2008	10	3000 ng/m ³	No	
5269867	7 - Roof, East Facade	12/31/2007	7:06 AM	1/1/2008	7:54 AM	1,488	551	Mercury	EPA 324/1631 mod.	BRL	01/03/2008	9	3000 ng/m ³	No	
5269871	8 - Roof, North Facade	12/31/2007	7:43 AM	1/1/2008	8:24 AM	1,481	578	Mercury	EPA 324/1631 mod.	BRL	01/03/2008	9	3000 ng/m ³	No	
5269879	3 - 90 West Courtyard at 2nd Floor Level	1/1/2008	8:52 AM	1/2/2008	7:09 AM	1,337	535	Mercury	EPA 324/1631 mod.	BRL	01/03/2008	12	3000 ng/m ³	No	
5269883	4 - Albany St 6th Floor Scaffolding	1/1/2008	7:49 AM	1/2/2008	7:27 AM	1,418	560	Mercury	EPA 324/1631 mod.	BRL	01/03/2008	12	3000 ng/m ³	No	
5269887	5 - Washington St 6th Floor Scaffolding	1/1/2008	8:04 AM	1/2/2008	7:38 AM	1,414	594	Mercury	EPA 324/1631 mod.	BRL	01/03/2008	10	3000 ng/m ³	No	
5269891	6 - Cedar St 6th Floor Scaffolding	1/1/2008	8:23 AM	1/2/2008	7:53 AM	1,410	578	Mercury	EPA 324/1631 mod.	BRL	01/03/2008	8	3000 ng/m ³	No	
5269895	7 - Roof, East Facade	1/1/2008	8:14 AM	1/2/2008	7:05 AM	1,371	542	Mercury	EPA 324/1631 mod.	BRL	01/03/2008	10	3000 ng/m ³	No	
5269899	8 - Roof, North Facade	1/1/2008	8:33 AM	1/2/2008	8:00 AM	1,407	556	Mercury	EPA 324/1631 mod.	BRL	01/03/2008	11	3000 ng/m ³	No	
5267073	3 - 90 West Courtyard at 2nd Floor Level	1/2/2008	7:16 AM	1/3/2008	7:11 AM	1,435	596	Mercury	EPA 324/1631 mod.	BRL	01/04/2008	< 5	3000 ng/m ³	No	
5267069	4 - Albany St 6th Floor Scaffolding	1/2/2008	7:33 AM	1/3/2008	7:29 AM	1,436	567	Mercury	EPA 324/1631 mod.	BRL	01/04/2008	< 5	3000 ng/m ³	No	
5267077	5 - Washington St 6th Floor Scaffolding	1/2/2008	7:43 AM	1/3/2008	7:42 AM	1,439	604	Mercury	EPA 324/1631 mod.	BRL	01/04/2008	< 5	3000 ng/m ³	No	
5267061	6 - Cedar St 6th Floor Scaffolding	1/2/2008	7:58 AM	1/3/2008	8:03 AM	1,445	578	Mercury	EPA 324/1631 mod.	BRL	01/04/2008	< 5	3000 ng/m ³	No	
5267047	7 - Roof, East Facade	1/2/2008	10:09 AM	1/3/2008	9:40 AM	1,411	572	Mercury	EPA 324/1631 mod.	BRL	01/04/2008	< 5	3000 ng/m ³	No	
5267057	7 - Roof, East Facade	1/2/2008	7:14 AM	1/3/2008	6:59 AM	1,425	577	Mercury	EPA 324/1631 mod.	BRL	01/04/2008	6	3000 ng/m ³	No	
5267053	8 - Roof, North Facade	1/2/2008	8:09 AM	1/3/2008	7:48 AM	1,419	539	Mercury	EPA 324/1631 mod.	BRL	01/04/2008	< 6	3000 ng/m ³	No	
5269797	3 - 90 West Courtyard at 2nd Floor Level	1/3/2008	7:16 AM	1/4/2008	7:12 AM	1,436	567	Mercury	EPA 324/1631 mod.	BRL	01/05/2008	< 5	3000 ng/m ³	No	
5267504	4 - Albany St 6th Floor Scaffolding	1/3/2008	7:44 AM	1/4/2008	7:37 AM	1,433	559	Mercury	EPA 324/1631 mod.	BRL	01/05/2008	< 6	3000 ng/m ³	No	
5267508	5 - Washington St 6th Floor Scaffolding	1/3/2008	7:55 AM	1/4/2008	7:50 AM	1,435	574	Mercury	EPA 324/1631 mod.	BRL	01/05/2008	< 5	3000 ng/m ³	No	
5267512	6 - Cedar St 6th Floor Scaffolding	1/3/2008	8:11 AM	1/4/2008	8:04 AM	1,433	559	Mercury	EPA 324/1631 mod.	BRL	01/05/2008	< 6	3000 ng/m ³	No	
5267516	7 - Roof, East Facade	1/3/2008	7:10 AM	1/4/2008	7:10 AM	1,440	590	Mercury	EPA 324/1631 mod.	BRL	01/05/2008	< 5	3000 ng/m ³	No	
5267520	8 - Roof, North Facade	1/3/2008	8:01 AM	1/4/2008	7:46 AM	1,425	584	Mercury	EPA 324/1631 mod.	BRL	01/05/2008	< 5	3000 ng/m ³	No	
5267537	3 - 90 West Courtyard at 2nd Floor Level	1/4/2008	7:19 AM	1/5/2008	7:14 AM	1,435	553	Mercury	EPA 324/1631 mod.	BRL	01/07/2008	< 6	3000 ng/m ³	No	
5267541	4 - Albany St 6th Floor Scaffolding	1/4/2008	7:41 AM	1/5/2008	7:35 AM	1,434	545	Mercury	EPA 324/1631 mod.	BRL	01/07/2008	< 6	3000 ng/m ³	No	
5267545	5 - Washington St 6th Floor Scaffolding	1/4/2008	7:54 AM	1/5/2008	7:47 AM	1,433	566	Mercury	EPA 324/1631 mod.	BRL	01/07/2008	< 5	3000 ng/m ³	No	
5267549	6 - Cedar St 6th Floor Scaffolding	1/4/2008	8:08 AM	1/5/2008	8:00 AM	1,432	530	Mercury	EPA 324/1631 mod.	BRL	01/07/2008	< 6	3000 ng/m ³	No	
5267553	7 - Roof, East Facade	1/4/2008	7:20 AM	1/5/2008	7:02 AM	1,422	540	Mercury	EPA 324/1631 mod.	BRL	01/07/2008	< 6	3000 ng/m ³	No	
5267557	8 - Roof, North Facade	1/4/2008	7:56 AM	1/5/2008	7:41 AM	1,425	570	Mercury	EPA 324/1631 mod.	BRL	01/07/2008	< 5	3000 ng/m ³	No	
5267565	3 - 90 West Courtyard at 2nd Floor Level	1/5/2008	7:19 AM	1/6/2008	7:47 AM	1,468	587	Mercury	EPA 324/1631 mod.	BRL	01/08/2008	< 5	3000 ng/m ³	No	
5267569	4 - Albany St 6th Floor Scaffolding	1/5/2008	7:39 AM	1/6/2008	8:21 AM	1,482	459	Mercury	EPA 324/1631 mod.	BRL	01/08/2008	< 7	3000 ng/m ³	No	
5267573	5 - Washington St 6th Floor Scaffolding	1/5/2008	7:51 AM	1/6/2008	8:39 AM	1,488	580	Mercury	EPA 324/1631 mod.	BRL	01/08/2008	< 5	3000 ng/m ³	No	
5267577	6 - Cedar St 6th Floor Scaffolding	1/5/2008	8:05 AM	1/6/2008	8:55 AM	1,490	633	Mercury	EPA 324/1631 mod.	BRL	01/08/2008	< 5	3000 ng/m ³	No	
5267581	7 - Roof, East Facade	1/5/2008	7:09 AM	1/6/2008	7:25 AM	1,456	561	Mercury	EPA 324/1631 mod.	BRL	01/08/2008	< 5	3000 ng/m ³	No	
5267585	8 - Roof, North Facade	1/5/2008	7:50 AM	1/6/2008	7:55 AM	1,445	549	Mercury	EPA 324/1631 mod.	BRL	01/08/2008	< 6	3000 ng/m ³	No	

MasterWorks - 130 Cedar Building, Community Monitoring

Sample No.	Sampling Location	Collection Start Date	Collection (Time on)	Collection End Date	Collection (Time off)	Total Collection Time, minutes	Volume (liters)	Analysis	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos Concentration (f/cc)	MMVF Concentration (f/cc)	EPA Site Specific Trigger Level	Exceeds EPA Site Specific Trigger Level?	Comments
5268145	3 - 90 West Courtyard at 2nd Floor Level	12/30/2007	7:34 AM	12/31/2007	7:08 AM	1,414	3,995	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/2/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5268149	4 - Albany St 6th Floor Scaffolding	12/30/2007	7:51 AM	12/31/2007	7:31 AM	1,420	4,118	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/2/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5268153	5 - Washington St 6th Floor Scaffolding	12/30/2007	8:06 AM	12/31/2007	7:45 AM	1,419	4,186	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/2/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5268157	6 - Cedar St 6th Floor Scaffolding	12/30/2007	8:20 AM	12/31/2007	8:00 AM	1,420	4,189	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/2/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5268161	7 - Roof, East Facade	12/30/2007	7:27 AM	12/31/2007	6:56 AM	1,409	4,151	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/2/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5268165	8 - Roof, North Facade	12/30/2007	7:51 AM	12/31/2007	7:32 AM	1,421	4,176	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/2/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5269850	3 - 90 West Courtyard at 2nd Floor Level	12/31/2007	8:31 AM	1/1/2008	8:49 AM	1,458	4,374	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/3/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5269854	4 - Albany St 6th Floor Scaffolding	12/31/2007	7:55 AM	1/1/2008	7:46 AM	1,431	4,293	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/3/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5269858	5 - Washington St 6th Floor Scaffolding	12/31/2007	7:49 AM	1/1/2008	8:00 AM	1,451	4,099	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/3/2008	N/A	N/A	0.0009 f/cc	N/A	Sample Voided at lab - Filter misloaded in cassette
5269862	6 - Cedar St 6th Floor Scaffolding	12/31/2007	8:04 AM	1/1/2008	8:19 AM	1,455	4,183	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/3/2008	<0.00005	0.00005	0.0009 f/cc	No	
5269866	7 - Roof, East Facade	12/31/2007	8:03 AM	1/1/2008	7:52 AM	1,429	4,413	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/3/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5269870	8 - Roof, North Facade	12/31/2007	8:12 AM	1/1/2008	8:20 AM	1,448	4,362	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/3/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5269878	3 - 90 West Courtyard at 2nd Floor Level	1/1/2008	8:52 AM	1/2/2008	7:09 AM	1,337	4,011	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/3/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5269882	4 - Albany St 6th Floor Scaffolding	1/1/2008	7:49 AM	1/2/2008	7:27 AM	1,418	4,219	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/3/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5269886	5 - Washington St 6th Floor Scaffolding	1/1/2008	8:04 AM	1/2/2008	7:38 AM	1,414	4,101	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/3/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5269890	6 - Cedar St 6th Floor Scaffolding	1/1/2008	8:23 AM	1/2/2008	7:53 AM	1,410	4,230	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/3/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5269894	7 - Roof, East Facade	1/1/2008	8:06 AM	1/2/2008	7:05 AM	1,379	4,106	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/3/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5269898	8 - Roof, North Facade	1/1/2008	8:27 AM	1/2/2008	8:00 AM	1,413	4,251	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/3/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5267072	3 - 90 West Courtyard at 2nd Floor Level	1/2/2008	7:16 AM	1/3/2008	7:11 AM	1,435	4,341	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/4/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5267068	4 - Albany St 6th Floor Scaffolding	1/2/2008	7:33 AM	1/3/2008	7:29 AM	1,436	4,236	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/4/2008	<0.00005	0.00005	0.0009 f/cc	No	
5267076	5 - Washington St 6th Floor Scaffolding	1/2/2008	7:43 AM	1/3/2008	7:42 AM	1,439	4,497	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/4/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5267060	6 - Cedar St 6th Floor Scaffolding	1/2/2008	7:58 AM	1/3/2008	8:03 AM	1,445	4,335	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/4/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5267046	7 - Roof, East Facade	1/2/2008	7:33 AM	1/3/2008	7:30 AM	1,437	4,557	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/4/2008	<0.00004	<0.00004	0.0009 f/cc	No	
5267056	7 - Roof, East Facade	1/2/2008	7:14 AM	1/3/2008	6:59 AM	1,425	4,330	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/4/2008	<0.00005	0.00009	0.0009 f/cc	No	
5267052	8 - Roof, North Facade	1/2/2008	8:09 AM	1/3/2008	7:48 AM	1,419	4,301	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/4/2008	0.00009	<0.00005	0.0009 f/cc	No	
5269796	3 - 90 West Courtyard at 2nd Floor Level	1/3/2008	7:16 AM	1/4/2008	7:12 AM	1,436	4,236	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/5/2008	0.00005	<0.00005	0.0009 f/cc	No	
5267503	4 - Albany St 6th Floor Scaffolding	1/3/2008	7:44 AM	1/4/2008	7:37 AM	1,433	4,299	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/5/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5267507	5 - Washington St 6th Floor Scaffolding	1/3/2008	7:55 AM	1/4/2008	7:50 AM	1,435	4,305	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/5/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5267511	6 - Cedar St 6th Floor Scaffolding	1/3/2008	8:11 AM	1/4/2008	8:04 AM	1,433	4,371	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/5/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5267515	7 - Roof, East Facade	1/3/2008	7:10 AM	1/4/2008	7:10 AM	1,440	4,548	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/5/2008	<0.00004	<0.00004	0.0009 f/cc	No	
5267519	8 - Roof, North Facade	1/3/2008	8:01 AM	1/4/2008	7:46 AM	1,425	4,466	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/5/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5267536	3 - 90 West Courtyard at 2nd Floor Level	1/4/2008	7:19 AM	1/5/2008	7:14 AM	1,435	4,233	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/7/2008	0.00005	<0.00005	0.0009 f/cc	No	
5267540	4 - Albany St 6th Floor Scaffolding	1/4/2008	7:41 AM	1/5/2008	7:35 AM	1,434	4,374	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/7/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5267544	5 - Washington St 6th Floor Scaffolding	1/4/2008	7:54 AM	1/5/2008	7:47 AM	1,433	4,442	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/7/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5267548	6 - Cedar St 6th Floor Scaffolding	1/4/2008	8:08 AM	1/5/2008	8:00 AM	1,432	4,368	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/7/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5267552	7 - Roof, East Facade	1/4/2008	7:20 AM	1/5/2008	7:02 AM	1,422	4,372	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/7/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5267556	8 - Roof, North Facade	1/4/2008	7:56 AM	1/5/2008	7:41 AM	1,425	4,364	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/7/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5267564	3 - 90 West Courtyard at 2nd Floor Level	1/5/2008	7:19 AM	1/6/2008	7:47 AM	1,468	4,184	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/8/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5267568	4 - Albany St 6th Floor Scaffolding	1/5/2008	7:39 AM	1/6/2008	8:21 AM	1,482	4,224	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/8/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5267572	5 - Washington St 6th Floor Scaffolding	1/5/2008	7:51 AM	1/6/2008	8:39 AM	1,488	4,315	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/8/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5267576	6 - Cedar St 6th Floor Scaffolding	1/5/2008	8:05 AM	1/6/2008	8:55 AM	1,490	4,321	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/8/2008	<0.00005	<0.00005	0.0009 f/cc	No	
5267580	7 - Roof, East Facade	1/5/2008	7:09 AM	1/6/2008	7:25 AM	1,456	4,485	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/8/2008	<0.00005	0.00005	0.0009 f/cc	No	
5267584	8 - Roof, North Facade	1/5/2008	7:50 AM	1/6/2008	7:55 AM	1,445	4,278	Asbestos PCME fibers	ISO 14966 mod	RJLG SEM	1/8/2008	<0.00005	<0.00005	0.0009 f/cc	No	


Sample No.	Sampling Location	Collection Start Date	Collection (Time on)	Collection End Date	Collection (Time off)	Total collection time, minutes	Sample Volume (liters)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Respirable Dust Concentration (mg/m ³)	Respirable Quartz Concentration (mg/m ³)	Target Air quality Level for Respirable Quartz (mg/m ³)	EPA Site Specific Trigger Level for Respirable Quartz (mg/m ³)	Exceeds Target Air quality or EPA Site Specific Level?	Comments
5268144	3 - 90 West Courtyard at 2nd Floor Level	12/30/2007	7:34 AM	12/31/2007	7:08 AM	1,414	3,464	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/2/2008	< 0.029	< 0.001	0.01	0.01	No	
5268148	4 - Albany St 6th Floor Scaffolding	12/30/2007	7:51 AM	12/31/2007	7:31 AM	1,420	3,373	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/2/2008	< 0.038	< 0.001	0.01	0.01	No	
5268152	5 - Washington St 6th Floor Scaffolding	12/30/2007	8:08 AM	12/31/2007	7:45 AM	1,419	3,477	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/2/2008	< 0.029	< 0.001	0.01	0.01	No	
5268156	6 - Cedar St 6th Floor Scaffolding	12/30/2007	8:20 AM	12/31/2007	8:00 AM	1,420	3,550	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/2/2008	< 0.028	< 0.001	0.01	0.01	No	
5268160	7 - Roof, East Facade	12/30/2007	12:46 PM	12/31/2007	6:56 AM	1,090	2,698	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/2/2008	< 0.037	< 0.002	0.01	0.01	No	
5268164	8 - Roof, North Facade	12/30/2007	7:51 AM	12/31/2007	7:32 AM	1,421	3,462	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/2/2008	< 0.029	< 0.001	0.01	0.01	No	
5268949	3 - 90 West Courtyard at 2nd Floor Level	12/31/2007	7:12 AM	1/1/2008	6:48 AM	1,537	4,073	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/3/2008	< 0.025	< 0.001	0.01	0.01	No	
5268953	4 - Albany St 6th Floor Scaffolding	12/31/2007	7:34 AM	1/1/2008	7:46 AM	1,452	3,412	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/3/2008	< 0.029	< 0.001	0.01	0.01	No	
5268957	5 - Washington St 6th Floor Scaffolding	12/31/2007	7:49 AM	1/1/2008	8:00 AM	1,451	3,628	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/3/2008	< 0.028	< 0.001	0.01	0.01	No	
5268961	6 - Cedar St 6th Floor Scaffolding	12/31/2007	8:04 AM	1/1/2008	8:19 AM	1,455	3,565	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/3/2008	< 0.028	< 0.001	0.01	0.01	No	
5268965	7 - Roof, East Facade	12/31/2007	7:06 AM	1/1/2008	7:50 AM	1,484	3,784	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/3/2008	< 0.026	< 0.001	0.01	0.01	No	
5268969	8 - Roof, North Facade	12/31/2007	7:43 AM	1/1/2008	8:18 AM	1,475	3,835	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/3/2008	< 0.026	< 0.001	0.01	0.01	No	
5268977	3 - 90 West Courtyard at 2nd Floor Level	1/1/2008	8:52 AM	1/2/2008	7:09 AM	1,337	3,343	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/3/2008	< 0.030	< 0.001	0.01	0.01	No	
5268981	4 - Albany St 6th Floor Scaffolding	1/1/2008	7:49 AM	1/2/2008	7:27 AM	1,418	3,545	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/3/2008	< 0.028	< 0.001	0.01	0.01	No	
5268985	5 - Washington St 6th Floor Scaffolding	1/1/2008	8:04 AM	1/2/2008	7:38 AM	1,414	3,535	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/3/2008	< 0.028	< 0.001	0.01	0.01	No	
5268989	6 - Cedar St 6th Floor Scaffolding	1/1/2008	8:23 AM	1/2/2008	7:53 AM	1,410	3,525	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/3/2008	< 0.028	< 0.001	0.01	0.01	No	
5268993	7 - Roof, East Facade	1/1/2008	8:08 AM	1/2/2008	7:05 AM	1,377	3,374	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/3/2008	< 0.030	< 0.001	0.01	0.01	No	
5268997	8 - Roof, North Facade	1/1/2008	8:31 AM	1/2/2008	8:00 AM	1,409	3,452	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/3/2008	< 0.029	< 0.001	0.01	0.01	No	
5267045	7 - Roof, East Facade	1/2/2008	7:33 AM	1/3/2008	7:30 AM	1,437	3,664	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/4/2008	< 0.027	< 0.001	0.01	0.01	No	
5267051	8 - Roof, North Facade	1/2/2008	8:09 AM	1/3/2008	7:48 AM	1,419	3,477	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/4/2008	< 0.029	< 0.001	0.01	0.01	No	
5267055	7 - Roof, East Facade	1/2/2008	7:14 AM	1/3/2008	6:59 AM	1,425	3,491	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/4/2008	< 0.029	< 0.001	0.01	0.01	No	
5267059	6 - Cedar St 6th Floor Scaffolding	1/2/2008	7:59 AM	1/3/2008	8:03 AM	1,445	3,468	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/4/2008	< 0.029	< 0.001	0.01	0.01	No	
5267067	4 - Albany St 6th Floor Scaffolding	1/2/2008	7:33 AM	1/3/2008	7:29 AM	1,436	3,375	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/4/2008	< 0.030	< 0.001	0.01	0.01	No	
5267071	3 - 90 West Courtyard at 2nd Floor Level	1/2/2008	7:16 AM	1/3/2008	7:11 AM	1,435	3,229	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/4/2008	< 0.022	< 0.001	0.01	0.01	No	
5267075	5 - Washington St 6th Floor Scaffolding	1/2/2008	7:43 AM	1/3/2008	7:42 AM	1,439	3,526	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/4/2008	< 0.028	< 0.001	0.01	0.01	No	
5267506	6 - Cedar St 6th Floor Scaffolding	1/3/2008	7:55 AM	1/4/2008	7:50 AM	1,435	3,659	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/5/2008	< 0.027	< 0.001	0.01	0.01	No	
5267510	6 - Cedar St 6th Floor Scaffolding	1/3/2008	8:11 AM	1/4/2008	8:04 AM	1,433	3,654	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/5/2008	< 0.027	< 0.001	0.01	0.01	No	
5267514	7 - Roof, East Facade	1/3/2008	7:10 AM	1/4/2008	7:10 AM	1,440	3,744	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/5/2008	< 0.027	< 0.001	0.01	0.01	No	
5267518	8 - Roof, North Facade	1/3/2008	8:01 AM	1/4/2008	7:46 AM	1,425	3,705	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/5/2008	< 0.027	< 0.001	0.01	0.01	No	
5268503	4 - Albany St 6th Floor Scaffolding	1/3/2008	7:44 AM	1/4/2008	7:37 AM	1,433	3,583	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/5/2008	< 0.027	< 0.001	0.01	0.01	No	
5268795	3 - 90 West Courtyard at 2nd Floor Level	1/3/2008	7:19 AM	1/4/2008	7:12 AM	1,436	3,662	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/5/2008	< 0.027	< 0.001	0.01	0.01	No	
5268735	3 - 90 West Courtyard at 2nd Floor Level	1/4/2008	7:16 AM	1/5/2008	7:14 AM	1,435	3,659	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/7/2008	< 0.027	< 0.001	0.01	0.01	No	
5267539	4 - Albany St 6th Floor Scaffolding	1/4/2008	7:41 AM	1/5/2008	7:35 AM	1,434	3,657	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/7/2008	< 0.027	< 0.001	0.01	0.01	No	
5267543	5 - Washington St 6th Floor Scaffolding	1/4/2008	7:54 AM	1/5/2008	7:47 AM	1,433	3,654	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/7/2008	< 0.028	< 0.001	0.01	0.01	No	
5267547	6 - Cedar St 6th Floor Scaffolding	1/4/2008	8:08 AM	1/5/2008	8:00 AM	1,432	3,580	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/7/2008	< 0.028	< 0.001	0.01	0.01	No	
5267551	7 - Roof, East Facade	1/4/2008	7:20 AM	1/5/2008	7:02 AM	1,422	3,697	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/7/2008	< 0.027	< 0.001	0.01	0.01	No	
5267555	8 - Roof, North Facade	1/4/2008	7:56 AM	1/5/2008	7:41 AM	1,425	3,705	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/7/2008	< 0.027	< 0.001	0.01	0.01	No	
5267563	3 - 90 West Courtyard at 2nd Floor Level	1/5/2008	7:19 AM	1/6/2008	7:47 AM	1,468	3,560	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/8/2008	0.033	< 0.001	0.01	0.01	No	
5267567	4 - Albany St 6th Floor Scaffolding	1/5/2008	7:39 AM	1/6/2008	8:21 AM	1,462	3,483	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/8/2008	< 0.029	< 0.001	0.01	0.01	No	
5267571	5 - Washington St 6th Floor Scaffolding	1/5/2008	7:51 AM	1/6/2008	8:39 AM	1,488	3,683	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/8/2008	< 0.027	< 0.001	0.01	0.01	No	
5267575	6 - Cedar St 6th Floor Scaffolding	1/5/2008	8:05 AM	1/6/2008	8:55 AM	1,490	3,576	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/8/2008	0.036	< 0.001	0.01	0.01	No	
5267579	7 - Roof, East Facade	1/5/2008	7:09 AM	1/6/2008	7:25 AM	1,456	3,640	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/8/2008	< 0.027	< 0.001	0.01	0.01	No	
5267583	8 - Roof, North Facade	1/5/2008	7:55 AM	1/6/2008	7:55 AM	1,445	3,613	Dust and Quartz	NIOSH 0600/7500	RJLG XRD	1/8/2008	< 0.028	< 0.001	0.01	0.01	No	

MasterWorks - 130 Cedar Building, Community Monitoring

Sample No.	Sampling Location	Collection Start Date	Collection (Time on)	Collection End Date	Collection (Time off)	Total Collection Time, minutes	Analysis	Analytical Method	Instrument	Lab Sample Receipt Date	PM _{2.5} Avg. Concentration (µg/m ³)	EPA Site Specific Trigger Level for PM _{2.5} (µg/m ³)	Exceeds Target Air quality or EPA Site Specific Level?	Comments
N/A	3 - Courtyard, 2nd Floor Level	12/30/2007	12:00 AM	12/31/2007	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4526	N/A	22	65	No	
N/A	4 - Albany St 6th Floor Level Scaffolding	12/30/2007	12:00 AM	12/31/2007	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4728	N/A	16	65	No	
N/A	5 - Washington St 6th Floor Level Scaffolding	12/30/2007	12:00 AM	12/31/2007	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4729	N/A	17	65	No	
N/A	6 - Cedar St 6th Floor Level Scaffolding	12/30/2007	12:00 AM	12/31/2007	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4527	N/A	22	65	No	
N/A	7 - Roof, East	12/30/2007	12:00 AM	12/31/2007	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # F5003	N/A	15	65	No	
N/A	8 - Roof, North	12/30/2007	12:00 AM	12/31/2007	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4607	N/A	16	65	No	
N/A	3 - Courtyard, 2nd Floor Level	12/31/2007	12:00 AM	1/1/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4526	N/A	17	65	No	
N/A	4 - Albany St 6th Floor Level Scaffolding	12/31/2007	12:00 AM	1/1/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4728	N/A	14	65	No	
N/A	5 - Washington St 6th Floor Level Scaffolding	12/31/2007	12:00 AM	1/1/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4729	N/A	16	65	No	
N/A	6 - Cedar St 6th Floor Level Scaffolding	12/31/2007	12:00 AM	1/1/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4527	N/A	20	65	No	
N/A	7 - Roof, East	12/31/2007	12:00 AM	1/1/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # F5003	N/A	15	65	No	
N/A	8 - Roof, North	12/31/2007	12:00 AM	1/1/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4607	N/A	17	65	No	
N/A	3 - Courtyard, 2nd Floor Level	1/1/2008	12:00 AM	1/2/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4526	N/A	19	65	No	
N/A	4 - Albany St 6th Floor Level Scaffolding	1/1/2008	12:00 AM	1/2/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4728	N/A	19	65	No	
N/A	5 - Washington St 6th Floor Level Scaffolding	1/1/2008	12:00 AM	1/2/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4729	N/A	23	65	No	
N/A	6 - Cedar St 6th Floor Level Scaffolding	1/1/2008	12:00 AM	1/2/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4527	N/A	29	65	No	
N/A	7 - Roof, East	1/1/2008	12:00 AM	1/2/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # F5003	N/A	18	65	No	
N/A	8 - Roof, North	1/1/2008	12:00 AM	1/2/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4607	N/A	20	65	No	
N/A	3 - Courtyard, 2nd Floor Level	1/2/2008	12:00 AM	1/3/2008	12:00 AM	1,435	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4526	N/A	10	65	No	
N/A	4 - Albany St 6th Floor Level Scaffolding	1/2/2008	12:00 AM	1/3/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4728	N/A	9	65	No	
N/A	5 - Washington St 6th Floor Level Scaffolding	1/2/2008	12:00 AM	1/3/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4729	N/A	8	65	No	
N/A	6 - Cedar St 6th Floor Level Scaffolding	1/2/2008	12:00 AM	1/3/2008	12:00 AM	1,435	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4527	N/A	10	65	No	
N/A	7 - Roof, East	1/2/2008	12:00 AM	1/3/2008	12:00 AM	1,435	PM _{2.5}	Direct Read	Met One E-BAM Unit # F5003	N/A	8	65	No	
N/A	8 - Roof, North	1/2/2008	12:00 AM	1/3/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4607	N/A	9	65	No	
N/A	3 - Courtyard, 2nd Floor Level	1/3/2008	12:00 AM	1/4/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4526	N/A	8	65	No	
N/A	4 - Albany St 6th Floor Level Scaffolding	1/3/2008	12:00 AM	1/4/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4728	N/A	8	65	No	
N/A	5 - Washington St 6th Floor Level Scaffolding	1/3/2008	12:00 AM	1/4/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4729	N/A	8	65	No	
N/A	6 - Cedar St 6th Floor Level Scaffolding	1/3/2008	12:00 AM	1/4/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4527	N/A	8	65	No	
N/A	7 - Roof, East	1/3/2008	12:00 AM	1/4/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # F5003	N/A	7	65	No	
N/A	8 - Roof, North	1/3/2008	12:00 AM	1/4/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4607	N/A	8	65	No	
N/A	3 - Courtyard, 2nd Floor Level	1/4/2008	12:00 AM	1/5/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4526	N/A	18	65	No	
N/A	4 - Albany St 6th Floor Level Scaffolding	1/4/2008	12:00 AM	1/5/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4728	N/A	16	65	No	
N/A	5 - Washington St 6th Floor Level Scaffolding	1/4/2008	12:00 AM	1/5/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4729	N/A	21	65	No	
N/A	6 - Cedar St 6th Floor Level Scaffolding	1/4/2008	12:00 AM	1/5/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4527	N/A	19	65	No	
N/A	7 - Roof, East	1/4/2008	12:00 AM	1/5/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # F5003	N/A	16	65	No	
N/A	8 - Roof, North	1/4/2008	12:00 AM	1/5/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4607	N/A	18	65	No	
N/A	3 - Courtyard, 2nd Floor Level	1/5/2008	12:00 AM	1/6/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4526	N/A	24	65	No	
N/A	4 - Albany St 6th Floor Level Scaffolding	1/5/2008	12:00 AM	1/6/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4728	N/A	25	65	No	
N/A	5 - Washington St 6th Floor Level Scaffolding	1/5/2008	12:00 AM	1/6/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4729	N/A	26	65	No	
N/A	6 - Cedar St 6th Floor Level Scaffolding	1/5/2008	12:00 AM	1/6/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4527	N/A	29	65	No	
N/A	7 - Roof, East	1/5/2008	12:00 AM	1/6/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # F5003	N/A	25	65	No	
N/A	8 - Roof, North	1/5/2008	12:00 AM	1/6/2008	12:00 AM	1,440	PM _{2.5}	Direct Read	Met One E-BAM Unit # G4607	N/A	28	65	No	

MasterWorks - 130 Cedar Building, Community Monitoring														
Sample No.	Sampling Location	Collection Start Date	Collection (Time on)	Collection End Date	Collection (Time off)	Total Collection Time, minutes	Analysis	Analytical Method	Instrument	Lab Sample Receipt Date	PM ₁₀ Avg. Concentration (µg/m ³)	EPA Site Specific Trigger Level for PM10 (µg/m ³)	Exceeds Target Air quality or EPA Site Specific Level?	Comments
N/A	3 - Courtyard, 2nd Floor Level	12/30/2007	12:00 AM	12/31/2007	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4606	N/A	24	150	No	
N/A	4 - Albany St 6th Floor Level Scaffolding	12/30/2007	12:00 AM	12/31/2007	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4731	N/A	26	150	No	
N/A	5 - Washington St 6th Floor Level Scaffolding	12/30/2007	12:00 AM	12/31/2007	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4604	N/A	22	150	No	
N/A	6 - Cedar St 6th Floor Level Scaffolding	12/30/2007	12:00 AM	12/31/2007	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4605	N/A	36	150	No	
N/A	7 - Roof, East	12/30/2007	12:00 AM	12/31/2007	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # E3364	N/A	21	150	No	
N/A	8 - Roof, North	12/30/2007	12:00 AM	12/31/2007	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # F5001	N/A	34	150	No	
N/A	3 - Courtyard, 2nd Floor Level	12/31/2007	12:00 AM	01/01/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4606	N/A	26	150	No	
N/A	4 - Albany St 6th Floor Level Scaffolding	12/31/2007	12:00 AM	01/01/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4731	N/A	16	150	No	
N/A	5 - Washington St 6th Floor Level Scaffolding	12/31/2007	12:00 AM	01/01/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4604	N/A	21	150	No	
N/A	6 - Cedar St 6th Floor Level Scaffolding	12/31/2007	12:00 AM	01/01/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4605	N/A	33	150	No	
N/A	7 - Roof, East	12/31/2007	12:00 AM	01/01/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # E3364	N/A	21	150	No	
N/A	8 - Roof, North	12/31/2007	12:00 AM	01/01/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # F5001	N/A	30	150	No	
N/A	3 - Courtyard, 2nd Floor Level	1/1/2008	12:00 AM	01/02/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4606	N/A	32	150	No	
N/A	4 - Albany St 6th Floor Level Scaffolding	1/1/2008	12:00 AM	01/02/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4731	N/A	22	150	No	
N/A	5 - Washington St 6th Floor Level Scaffolding	1/1/2008	12:00 AM	01/02/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4604	N/A	28	150	No	
N/A	6 - Cedar St 6th Floor Level Scaffolding	1/1/2008	12:00 AM	01/02/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4605	N/A	34	150	No	
N/A	7 - Roof, East	1/1/2008	12:00 AM	01/02/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # E3364	N/A	27	150	No	
N/A	8 - Roof, North	1/1/2008	12:00 AM	01/02/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # F5001	N/A	39	150	No	
N/A	3 - Courtyard, 2nd Floor Level	1/2/2008	12:00 AM	01/03/2008	12:00 AM	1,435	PM ₁₀	Direct Read	Met One E-BAM Unit # G4606	N/A	12	150	No	
N/A	4 - Albany St 6th Floor Level Scaffolding	1/2/2008	12:00 AM	01/03/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4731	N/A	10	150	No	
N/A	5 - Washington St 6th Floor Level Scaffolding	1/2/2008	12:00 AM	01/03/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4604	N/A	11	150	No	
N/A	6 - Cedar St 6th Floor Level Scaffolding	1/2/2008	12:00 AM	01/03/2008	12:00 AM	1,435	PM ₁₀	Direct Read	Met One E-BAM Unit # G4605	N/A	13	150	No	
N/A	7 - Roof, East	1/2/2008	12:00 AM	01/03/2008	12:00 AM	1,435	PM ₁₀	Direct Read	Met One E-BAM Unit # E3364	N/A	14	150	No	
N/A	8 - Roof, North	1/2/2008	12:00 AM	01/03/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # F5001	N/A	15	150	No	
N/A	3 - Courtyard, 2nd Floor Level	1/3/2008	12:00 AM	01/04/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4606	N/A	10	150	No	
N/A	4 - Albany St 6th Floor Level Scaffolding	1/3/2008	12:00 AM	01/04/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4731	N/A	9	150	No	
N/A	5 - Washington St 6th Floor Level Scaffolding	1/3/2008	12:00 AM	01/04/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4604	N/A	11	150	No	
N/A	6 - Cedar St 6th Floor Level Scaffolding	1/3/2008	12:00 AM	01/04/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4605	N/A	10	150	No	
N/A	7 - Roof, East	1/3/2008	12:00 AM	01/04/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # E3364	N/A	11	150	No	
N/A	8 - Roof, North	1/3/2008	12:00 AM	01/04/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # F5001	N/A	17	150	No	
N/A	3 - Courtyard, 2nd Floor Level	1/4/2008	12:00 AM	01/05/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4606	N/A	20	150	No	
N/A	4 - Albany St 6th Floor Level Scaffolding	1/4/2008	12:00 AM	01/05/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4731	N/A	19	150	No	
N/A	5 - Washington St 6th Floor Level Scaffolding	1/4/2008	12:00 AM	01/05/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4604	N/A	24	150	No	
N/A	6 - Cedar St 6th Floor Level Scaffolding	1/4/2008	12:00 AM	01/05/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4605	N/A	25	150	No	
N/A	7 - Roof, East	1/4/2008	12:00 AM	01/05/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # E3364	N/A	23	150	No	
N/A	8 - Roof, North	1/4/2008	12:00 AM	01/05/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # F5001	N/A	22	150	No	
N/A	3 - Courtyard, 2nd Floor Level	1/5/2008	12:00 AM	01/06/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4606	N/A	30	150	No	
N/A	4 - Albany St 6th Floor Level Scaffolding	1/5/2008	12:00 AM	01/06/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4731	N/A	31	150	No	
N/A	5 - Washington St 6th Floor Level Scaffolding	1/5/2008	12:00 AM	01/06/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4604	N/A	31	150	No	
N/A	6 - Cedar St 6th Floor Level Scaffolding	1/5/2008	12:00 AM	01/06/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # G4605	N/A	34	150	No	
N/A	7 - Roof, East	1/5/2008	12:00 AM	1/6/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # E3364	N/A	34	150	No	
N/A	8 - Roof, North	1/5/2008	12:00 AM	1/6/2008	12:00 AM	1,440	PM ₁₀	Direct Read	Met One E-BAM Unit # F5001	N/A	35	150	No	

Mercury Vapor (Hg^0) Air Results for Outdoor Community
Monitoring Stations by Location as recorded by the Lumex Analyzer



Report Summary

Air Mercury Results (Hg^0 , ng/m^3) as recorded by the Lumex RA915+ analyzer
Week of 12/30/07 to 01/05/08

Date	Mercury (Hg^0) ng/m^3 30-sec readings	1 Southeast corner sidewalk bridge	2 Northeast corner sidewalk bridge	3 Courtyard 2nd floor level	4 Albany Street 6th floor scaffolding	5 Washington Street 6th floor scaffolding	6 Cedar Street 6th floor scaffolding	7 Roof Washington Street façade	8 Roof Cedar Street façade
30-Dec-07	# Samples	9	9	9	9	9	9	9	9
	Average	3	2	2	2	3	4	2	2
	Maximum	4	6	2	2	3	5	2	2
31-Dec-07	# Samples	18	18	21	18	18	18	18	18
	Average	2	2	6	2	2	2	2	2
	Maximum	3	2	10	2	2	4	2	3
1-Jan-08	# Samples	9	9	9	9	9	12	9	9
	Average	2	3	2	2	2	2	2	4
	Maximum	3	5	2	2	3	2	2	4
2-Jan-08	# Samples	18	18	18	18	18	18	18	18
	Average	2	4	9	2	2	2	2	2
	Maximum	3	6	18	2	2	4	4	4
3-Jan-08	# Samples	36	36	36	36	36	36	36	36
	Average	2	3	6	2	2	2	2	2
	Maximum	2	5	24	5	5	3	3	5
4-Jan-08	# Samples	45	45	27	45	45	45	45	45
	Average	2	3	5	2	2	2	2	2
	Maximum	7	10	8	8	7	6	5	6
5-Jan-08	# Samples	9	9	9	9	9	9	9	9
	Average	2	4	3	3	2	2	2	2
	Maximum	2	4	4	4	2	2	2	2